


ADDENDUM #3
1429 Max Hooks Road Widening and Resurfacing
Project No. 2008-02
Bid No. 08-0007

This addendum is being issued to make the following changes, corrections, clarifications and additions to the bidding document. The information in this addendum modifies and changes the original bidding documents and takes precedence over the original documents. **Receipt of this addendum shall be acknowledged by the bidder by signing and dating the appropriate line on page W-4 of the bid proposal.** Failure to acknowledge this addendum may preclude consideration of the bid proposal for award.

Questions and Answers

- Q.** Addendum # 1 states the road will be milled and 2' shoulders will be added. The typical in the plans indicate the new roadway is to have a 24' total width. Is it the intention to widen the existing pavement and add 2' paved shoulders to achieve the 24' width or to just add the 2' paved shoulders to the existing pavement?
- A.** The total width shall be 24' wide per the typical section; striped 10' travel lanes and 2' paved shoulders.

Approved by:


Jeff Johnson, Construction Inspector Manager

:smcd